

Entertainment Services and
Technology Association



American National Standard
E1.22 - 2009
Entertainment Technology
Fire Safety Curtain Systems

[inside front cover]

Entertainment Services and Technology Association



American National Standard E1.22 - 2009 Entertainment Technology Fire Safety Curtain Systems

Rig/2002-2032r9.1

This document was approved as an American National Standard by the ANSI Board of Standards Review on 21 April 2009.

[This page is intentionally blank.]

Notice and Disclaimer

The Entertainment Services and Technology Association does not approve, inspect, or certify any installations, procedures, equipment or materials for compliance with codes, recommended practices or standards. Compliance with an ESTA standard or recommended practice, or an American National Standard developed by ESTA is the sole and exclusive responsibility of the manufacturer or provider and is entirely within their control and discretion. Any markings, identification or other claims of compliance do not constitute certification or approval of any type or nature whatsoever by ESTA.

ESTA neither guarantees nor warrants the accuracy or completeness of any information published herein and disclaim liability for any personal injury, property or other damage or injury of any nature whatsoever, whether special, indirect, consequential or compensatory, directly or indirectly resulting from the publication, use of, or reliance on this document.

In issuing and distributing this document, ESTA does not either (a) undertake to render professional or other services for or on behalf of any person or entity, or (b) undertake any duty to any person or entity with respect to this document or its contents. Anyone using this document should rely on his or her own independent judgment or, as appropriate, seek the advice of a competent professional in determining the exercise of reasonable care in any given circumstance.

Published by:

Entertainment Services and Technology Association
875 Sixth Avenue, Suite 1005
New York, NY 10001 USA
Phone: 1-212-244-1505
Fax: 1-212-244-1502
standards@esta.org
<http://www.esta.org/>

For additional copies of this document contact:

ESTA Publications
The ESTA Foundation
875 Sixth Avenue, Suite 1005
New York, NY 10001 USA
Phone: 1-212-244-1505
Fax: 1-212-244-1502
<http://www.estafoundation.org>

The ESTA Technical Standards Program

The ESTA Technical Standards Program was created to serve the ESTA membership and the entertainment industry in technical standards related matters. The goal of the Program is to take a leading role regarding technology within the entertainment industry by creating recommended practices and standards, monitoring standards issues around the world on behalf of our members, and improving communications and safety within the industry. ESTA works closely with the technical standards efforts of other organizations within our industry, including USITT, PLASA, and VPLT, as well as representing the interests of ESTA members to ANSI, UL, and the NFPA. The Technical Standards Program is accredited by the American National Standards Institute.

The Technical Standards Committee (TSC) was established by ESTA's Board of Directors to oversee and coordinate the Technical Standards Program. Made up of individuals experienced in standards-making work from throughout our industry, the Committee approves all projects undertaken and assigns them to the appropriate working group. The Technical Standards Committee employs a Technical Standards Manager to coordinate the work of the Committee and its working groups as well as maintain a "Standards Watch" on behalf of members. Working groups include: Camera Cranes, Control Protocols, Electrical Power, Floors, Fog and Smoke, Followspot Position, Photometrics, and Rigging.

ESTA encourages active participation in the Technical Standards Program. There are several ways to become involved. If you would like to become a member of an existing working group, as have over two hundred people, you must complete an application which is available from the ESTA office. Your application is subject to approval by the working group and you will be required to actively participate in the work of the group. This includes responding to letter ballots and attending meetings. Membership in ESTA is not a requirement. You can also become involved by requesting that the TSC develop a standard or a recommended practice in an area of concern to you.

The Rigging Working Group, which authored this Standard, consists of a cross section of entertainment industry professionals representing a diversity of interests related to rigging and stage machinery for theatrical events. ESTA is committed to developing consensus-based standards and recommended practices in an open setting. Future Rigging Working Group projects will include updating this publication as changes in technology and experience warrant, as well as developing new standards and recommended practices for the benefit of the entertainment industry.

Contact Information

Entertainment Services and Technology Association

Karl G. Ruling
Technical Standards Manager
ESTA
875 Sixth Avenue, Suite 1005
New York, NY 10001
Phone: 1-212-244-1505
FAX: 1-212-244-1502
standards@esta.org

Technical Standards Committee Chairperson

Mike Garl
James Thomas Engineering, Inc.
10240 Caneel Drive
Knoxville, TN 37931
Phone: 1-865-692-3060
FAX: 1-865-692-9020
mikeg@jthomaseng.com

Rigging Working Group Chairpersons

Bill Sapsis
Sapsis Rigging, Inc.
233 North Lansdowne Ave.
Lansdowne, PA 19050
Phone: 1-215-228-0888
FAX: 1-215-228-1786
bill@sapsis-rigging.com

Kent Jorgensen
IATSE Local 80
2520 West Olive
Burbank, CA 91505
Phone: 1-818-526-0701
FAX: 1-818-526-0711
safety@iatselocal80.org

Acknowledgments

The Rigging Working Group was the consensus body for the development of this Standard. The working group's membership at the time the working group approved this standard on 5 January 2009 is listed below:

Principal Voting Members

William Beautyman; Limelight Productions, Inc. [DR]
 Ron Bonner; PLASA [G]
 William Bradburn; Aerial Arts, Inc. [U]
 Vincent J. Cannavale; Motion Laboratories [CP]
 Michael J. Carnaby; Mikan Theatricals [DR]
 Joseph Champelli; Fisher Technical Services, Inc. [CP]
 William Conner; Bill Conner Associates LLC, representing the American Society of Theatre Consultants [U]
 Kimberly Corbett; Schuler Shook [G]
 Dan Culhane; SECOA [CP]
 Bruce Darden; Rigging Innovators, Inc. [CP]
 Don Dimitroff; Columbus McKinnon Corp. [MP]
 M. Brad Dittmer; Downhome Productions [U]
 Adrian Forbes-Black; Total Structures Inc. [MP]
 Mike Garl; James Thomas Engineering, Inc. [MP]
 Jerry Gorrell; Theatre Safety Programs [G]
 Steven Graham; R&M Materials Handling [MP]
 Pat Grenfell; Vortek Rigging Division of Daktronics Inc. [CP]
 Tim Hansen; Oasis Stage Werks [DR]
 Pete Happe; Walt Disney Imagineering [U]
 Donald A. Hoffend, Jr.; Avista Designs, LLC [G]
 Wendy Holt; Alliance of Motion Picture and Television Producers [G]
 Ted Jones; Chicago Spotlight, Inc. [U]
 Kent H. Jorgensen; IATSE Local 80 [G]
 Christine L. Kaiser; Syracuse Scenery & Stage Lighting Co., Inc. [DR]
 Edwin S. Kramer; IATSE Local 1 [U]
 Roger Lattin; IATSE Local 728 [U]
 Eugene Leitermann; Theatre Projects Consultants, Inc. [G]
 Jon Lenard; Applied Electronics [MP]
 Reid Neslage; H & H Specialties Inc. [MP]
 James Niesel; Arup [G]
 Richard J. Nix; Entertainment Structures Group [G]
 Rocky Paulson; Stage Rigging, Inc. [DR]
 Shawn Sack; Mountain Productions Inc. [DR]
 Bill Sapsis; Sapsis Rigging, Inc. [U]
 Peter A. Scheu; Scheu Consulting Services [G]
 Peter Christian Schmidtke ; Hollywood Lighting Services, Inc. [DR]
 Knut Skjonberg; Skjonberg Controls, Inc. [CP]
 Stephen G. Surratt; Texas Scenic Company [DR]
 Peter V. Svitavsky; J.R. Clancy Inc. [CP]
 Harvey Sweet; LA ProPoint, Inc. [DR]
 Steve Walker; Steve A. Walker & Associates [G]
 Charlie Weiner [U]
 Nathan Wells; Stage Technologies [MP]
 Jeff Wilkowski; Thern, Inc. [MP]

Alternate Voting Members

Tray Allen; James Thomas Engineering, Inc. [MP]
 Dana Bartholomew; Fisher Technical Services [CP]

Spencer Brown; Oasis Stage Werks [DR]
Daniel J. Clark; Entertainment Structures Group [G]
Joshua Grossman; Schuler Shook [G]
Herb Hart; Columbus McKinnon Corp. [MP]
Peter Herrmann; Motion Laboratories [CP]
David Herrmann; Motion Laboratories [CP]
Joe Ingle; R&M Materials Handling [MP]
Rodney F. Kaiser; J.R. Clancy Inc. [CP]
Theresa Kelley; Total Structures Inc. [MP]
Jerald Kraft; SECOA [CP]
Kyle Kusmer; Entertainment Structures Group [G]
Bob Medve; Limelight Productions, Inc. [DR]
Edward A. Paget; Vortek Rigging Division of Daktronics Inc. [CP]
Jeff Reder; Entertainment Structures Group [G]
John Ringelman; Stage Rigging, Inc. [DR]
Monica Skjonberg; Skjonberg Controls, Inc. [CP]
Steve Sweet; Theatre Projects Consultants, Inc. [G]
Elmer Veith; Total Structures, Inc. [MP]
Robert Voss; Vortek Rigging Division of Daktronics Inc. [CP]
Frank Willard; Syracuse Scenery & Stage Lighting Co., Inc. [DR]
R. Duane Wilson; George C. Izenour Associates, representing the American Society of Theatre Consultants [U]
Jake Winkelman; Vortek Rigging Division of Daktronics Inc. [CP]
Thomas S. Young; J.R. Clancy Inc. [CP]

Observer Members (Non-voting)

Warren A. Bacon [U]
Rinus Bakker; Rhino Rigs B.V. [G]
Robert Barbagallo; Solotech Inc. [DR]
Roger Barrett; Star Events Group Ltd. [DR]
F. Robert Bauer; F.R. Bauer & Associates, LLC [G]
Lee J. Bloch; Bloch Design Group, Inc. [G]
Keith Bohn; Tomcat USA, Inc. [MP]
Louis Bradfield [U]
Buddy Braile; Bestek Lighting & Staging [U]
Andre Broucke; ADB - TTV Technologies [MP]
John R. Burgess [U]
David M. Campbell; Geiger Engineers [G]
Ian Coles; Total Structures, Inc. [MP]
Gregory C. Collis; IATSE Local 16 [G]
Olan Cottrill; Staging Productions, Inc. [DR]
Randall W. A. Davidson; Risk International & Associates, Inc. [U]
Robert Dean; ZFX Inc. [CP]
François Deffarges; Nexo [MP]
Cristina Delboni; Feeling Structures [MP]
Michael Dileso; IATSE Local 481 [U]
Harry Donovan; Donovan Rigging, Inc. [G]
Noga Eilon-Bahar; Eilon Engineering Industrial Weighing Systems [MP]
James B. Evans; Mountain Productions Inc. [DR]
Jim Fletcher; American Sling Company, Inc. [MP]
Tim Franklin; Theta-Consulting [G]
Douglas Franz; QVC Network [U]
Jay O. Glerum; Jay O. Glerum & Associates, Inc. [U]
Rand Goddard; W.E. Palmer Co. [CP]
Reuben Goldberg; Technic Services [U]
Charles E. Gorgen [G]

Thomas M. Granucci; Associated Students, Cox Arena, San Diego State University [U]
 Robert A. Grenier Jr.; Ocean State Rigging Systems Inc. [DR]
 Delbert Hall; Hall Associates Inc. [U]
 Dean Hart; Stage Rigging, Inc. [U]
 Ben Hayes; Freedom Flying [G]
 Marc Hendriks; Prolyte [MP]
 Ted Hickey; OAP Audio Products [MP]
 Chris Higgs; Total Solutions Group [G]
 Wes Jenkins; Down Stage Right Industries [CP]
 Peter Johns; Total Structures, Inc. [MP]
 Gary Justesen; Oasis Stage Werks [DR]
 John Kaes [U]
 JoAnna Kamorin-Lloyd; Vincent Lighting Systems [U]
 Bradford A. Kegel; National Production Services Inc. [U]
 Michael Keppler; Bogen [MP]
 Nevin Kleege; Kleege Industries [U]
 Jon Lagerquist; South Coast Repertory [U]
 Mylan Lester; Creation Logics Ltd. [U]
 Michael Lichter; Electronic Theatre Controls GmbH [MP]
 Baer Long; Ninja Rigging [G]
 Dennis J. Lopez; Automatic Devices Co. [MP]
 Chuck McClelland; Jeamar Winches Inc. [MP]
 Richard C. Mecke; Texas Scenic Company [DR]
 Hank Miller; W.E. Palmer Co. [CP]
 Shaun Millington; SEW-Eurodrive, Inc. [MP]
 Timothy Mills; Geiger Engineers [G]
 Scott Mohr; R&R Cases and Cabinets [G]
 Mark Newlin; Texas Scenic Company [DR]
 Rikki Newman [U]
 Ed Nicholas; Theatrical Lighting Systems, Inc. [DR]
 Tracy Nunnally; Northern Illinois University [U]
 Howard R. Ott; D.E.O. Associates, Inc. [G]
 Michael Patterson; Pook Diemont & Ohl, Inc. [CP]
 Todd Petersen; Mixed Productions [U]
 G. Anthony Phillips; IATSE Local 16 [U]
 Christopher Purpura; Jones & Phillips Associates, Inc. [G]
 Joseph Rapiere; Parkhill, Smith & Cooper, Inc. [CP]
 Michael Reed; Reed Rigging, Inc. [U]
 Julie Rogers; City of Phoenix Civic Plaza [G]
 Michael L. Savage, Sr.; Middle Dept. Inspection Agency, Inc. [G]
 John C. Snook; Thermotex Industries Inc. [CP]
 Rob Stevenson; SEW-Eurodrive, Inc. [MP]
 Andy Sutton; AFX UK Ltd. [U]
 Joachim Stoecker; CAMCO GmbH [MP]
 John Van Lennep; Theatrix Inc. [DR]
 Michael G. Wiener; Aerial Rigging & Leasing, Inc. [U]
 Jiantong Wu; Beijing Special Engineering Design & Research Institute [G]

[CP] Custom-market producer
 [MP] Mass-market producer
 [DR] Dealer or rental company
 [U] User
 [G] General interest

Contents

Notice and Disclaimer	i
Contact Information	iii
Acknowledgments	iv
Contents	vii
1 General.....	1
1.1 Scope.....	1
1.2 Purpose.....	1
1.3 Equivalency.....	1
2 Definitions.....	1
3 Unframed Fire Safety Curtains.....	2
3.1 Identification	2
3.2 Fabric	2
3.3 Construction	3
3.4 Testing	3
4 Framed Fire Safety Curtains	3
4.1 Fire-resistance	3
4.2 Frame.....	4
4.3 Frame Members.....	4
4.4 Guide Assemblies	4
4.5 Fire Resistive Cover Material.....	4
5 Opening Proximity	5
6 Vertical Edges	5
7 Horizontal Edges	6
8 Bumpers	6
9 Battens	6
10 Rigging	6
11 Operation.....	6
12 Testing, Training, Maintenance, Inspection, and Repairs	8
12.1 Records.....	8
12.2 Pre-Acceptance Testing.....	8
12.3 Periodic User Testing.....	8
12.4 Annual Inspection	9
12.5 Maintenance	9
12.6 Repairs.....	9
Annex A, Examples	10
A.1 Fabric Fire Safety Curtain Construction	10
A.2 Unframed Straight-lift Fire Safety Curtain Systems.....	10
A.3 Brail Fire Safety Curtain Systems.....	11
Annex B, Supplemental Information.....	13

1 General

1.1 Scope

This standard governs the materials, fabrication, installation, operation, testing, and maintenance of fire safety curtain systems used for proscenium opening protection.

1.2 Purpose

1.2.1 Fire safety curtain systems shall be used where required by building codes, fire codes, or by the authority having jurisdiction.

1.2.2 Fire safety curtain systems shall work in conjunction with other building life and fire safety systems. (See Annex note B.1.2.2.)

1.2.3 Fire safety curtain systems shall protect occupants of the audience area from a fire on stage and shall in combination with other building life and fire safety systems provide occupants of the audience area sufficient time for safe and orderly egress.

1.2.4 The fire safety curtain shall reduce the transmission of radiant heat, block debris, and contribute to the control of smoke and gas movement.

1.3 Equivalency

The provisions of this standard are not intended to prevent the use of any material or to prohibit any design or method of fabrication not specifically prescribed by this standard, provided that any such alternative material, design or method of fabrication complies with the intent of the provisions of this standard, and that the material, method or work offered is, for the purpose intended, at least the equivalent of that prescribed in this standard in quality, strength, and effectiveness.

2 Definitions

2.1 Batten: A horizontal pipe, tube, or other structural shape in a pocket of or attached to a fire safety curtain.

2.2 Brail Fire Safety Curtain: An unframed fire safety curtain that is folded horizontally in an accordion fashion for storage.

2.3 Brail Fire Safety Curtain System: A system that opens and closes a brail fire safety curtain.

2.4 Bumper: A filled pocket of fabric located below the bottom batten or bottom member of a frame.

2.5 Fill: The set of yarns placed crosswise in the loom, interlaced with the warp, forming the crosswise threads in the fabric. Also known as cross machine direction.

2.6 Fire Safety Curtain: The actual barrier including the membrane, structural framing, and attached hardware that closes the proscenium opening.

2.7 Fire Safety Curtain System: A fire safety curtain with all required hardware and controls to form a complete, fully operable assembly. (See Annex note B.2.7.)

2.8 Framed Fire Safety Curtain: A curtain with rigid horizontal members in addition to the top and bottom batten connected by two or more rigid vertical members.

2.9 Labeled: Equipment or materials to which has been attached a label, symbol, or other identifying mark of an organization that is acceptable to the authority having jurisdiction and concerned with product

evaluation, that maintains periodic inspection of production of labeled equipment or materials, and by whose labeling the manufacturer indicates compliance with appropriate standards or performance in a specified manner.

2.10 Listed: Equipment, materials, or services included in a list published by an organization that is acceptable to the authority having jurisdiction and concerned with evaluation of products or services, that maintains periodic inspection of production of listed equipment, material, or service and meets appropriate designated standards or has been tested and found suitable for a specified purpose.

2.11 Multi-part Fire Safety Curtain System: A system that opens and closes multiple fire safety curtains with horizontal overlaps.

2.12 Noncombustible: A material that, in the form in which it is used and under the conditions anticipated, will not aid combustion or add appreciable heat to a fire. Materials, when tested in accordance with ASTM E136-04 Standard Test Method for Behavior of Materials in a Vertical Tube Furnace at 750 degrees C, and conforming to the criteria contained in Section 8 of the referenced standard, are considered as noncombustible.

2.13 Pressure Differential: The force exerted over the fire safety curtain system caused by the difference in air pressure on each side of the curtain.

2.14 Proscenium Opening: The main opening in the proscenium wall used for viewing performances.

2.15 Proscenium Wall: The wall that separates the stage from the audience area.

2.16 Qualified Person: A person who, by possession of a recognized degree or certificate of professional standing, or who by extensive knowledge, training and experience, has successfully demonstrated the ability to solve or resolve problems relating to the subject matter and work.

2.17 Straight Lift Fire Safety Curtain System: A system that opens and closes a fire safety curtain as one flat panel without bending or folding.

2.18 Unframed Fire Safety Curtain: A curtain without rigid horizontal members other than the top and bottom battens.

2.19 Vertical guide pockets: Partial enclosures on both the stage left and stage right sides of the proscenium opening on the proscenium wall that protects the edges and guides of a fire safety curtain system. (See Annex note B.2.19.)

2.20 Warp: The set of yarns placed lengthwise in the loom, crossed by and interlaced with the fill, forming the lengthwise threads in the fabric. Also known as machine direction.

3 Unframed Fire Safety Curtains

3.1 Identification

Fabric fire safety curtains shall be permanently identified per paragraph 3.3.5 and the fabric shall be listed as complying with the E119 fire tests described in paragraph 3.4. (See Annex note B.3.1.)

3.2 Fabric

3.2.1 The fabric shall have a tensile strength of not less than 7.14 kg/mm (400 pounds per inch) in both the warp and fill directions as tested in accordance with ASTM D5034-95(2001), Standard Test Method for Breaking Strength and Elongation of Textile Fabrics (Grab Test). (See Annex note B.3.2.1.)

3.2.2 The fabric shall not lose over 35% of the warp strength when subjected to 50 cycles in accordance with ASTM D4157-02 Standard Test Method for Abrasion Resistance of Textile Fabrics (Oscillatory

Cylinder Method) using the 100-grit emery paper as the abrasant, and using 26.7 newtons (6 pounds) tension and 13.3 newtons (3 pounds) compression force.

3.2.3 The fabric shall have a smoke density rating of 25 or less, as tested in accordance with ASTM E84-04 Standard Test Method for Surface Burning Characteristics of Building Materials.

3.2.4 The fabric shall have an air permeability of less than 7.62 cubic meters/min per square meter (25 cfm per sq ft) tested in accordance with ASTM D737-96 Test Method for Air Permeability of Textile Fabrics.

3.3 Construction

3.3.1 Exposed fabric edges shall be prevented from unraveling and shall not compromise the strength of the fabric. (See Annex note B.3.3.1.)

3.3.2 Fabric seaming shall not lessen the tensile strength of the fabric.

3.3.3 Top and bottom pockets shall be sized to permit insertion of battens where required.

3.3.4 Fire safety curtains shall be guided at the two opposite vertical edges for the full extent of travel.

3.3.5 The fire safety curtain shall have a label in a location that is visible and convenient for identification by the authority having jurisdiction after installation of the fire safety curtain system. The label shall include the name of the fire safety curtain manufacturer, product or style of fabric, date of manufacture, list of fire tests, and testing agency.

3.4 Testing

A sample of the fire safety curtain shall be tested in accordance with ASTM E119-00a Standard Test Methods for Fire Tests of Building Construction and Materials procedure applicable to nonbearing walls and partitions for a period of 30 minutes. The sample construction shall replicate the sewing of the full-sized curtain, shall have a minimum of two vertical seams, and a bottom pocket containing a minimum 5.95 kg/m (4 pounds/foot) batten. The sample shall overlap and seal the top and vertical furnace edges. The unexposed surface of the sample shall not glow during the testing procedure, and flame or smoke shall not penetrate the sample. Only the surface cleansing vapors created by the oven's elevating temperatures in the first minutes of the procedure shall be acceptable. Unexposed surface temperature measurements and hose stream testing shall not be required.

4 Framed Fire Safety Curtains

4.1 Fire-resistance

4.1.1 Fire-resistance ratings

The fire-resistance rating of materials shall be determined in accordance with the test procedures set forth in ASTM E 119-07 for a period of 20 minutes, or in accordance with the alternative methods listed below. Where materials, systems or devices that have not been tested as part of a fire-resistance-rated assembly are incorporated into the assembly, sufficient data shall be made available to show that the required fire-resistance rating is not reduced. Materials and methods of construction used to protect joints and penetrations in fire-resistance-rated coverings shall not reduce the required fire-resistance rating.

4.1.2 Alternative methods for determining fire resistance

The application of any of the alternative methods listed in this section shall be based on the fire exposure and acceptance criteria specified in ASTM E 119-07. The required fire resistance of a building element shall be permitted to be established by any of the following methods or procedures.

4.1.2.1 Fire-resistance designs documented in approved sources.

4.1.2.2 Prescriptive designs of fire-resistance-rated building elements as prescribed in Section 720 of the 2003 International Building Code.

4.1.2.3 Calculations in accordance with Section 721 of the 2003 International Building Code.

4.1.2.4 Engineering analysis based on a comparison of building element designs having fire-resistance ratings as determined by the test procedures set forth in ASTM E 119-07.

4.1.2.5 Alternative protection methods as allowed by Section 1.3.

4.1.3 Surface-burning characteristics

The fire resistive cover shall have a flame spread index of 75 or less and a smoke developed index of 450 or less when tested in accordance with ASTM E84-07.

4.2 Frame

4.2.1 The frame shall be designed to withstand the load combinations required by current AISC steel design standards or other applicable standards.

4.2.2 The slenderness ratio for compression members shall not exceed 200:1.

4.2.3 The frame shall be braced to maintain its shape and integrity in the event of a single lifeline or guide failure.

4.2.4 The frame shall consist of an assembly of horizontal members, vertical end members, intermediate vertical supports and bracing.

4.3 Frame Members

4.3.1 Framing shall be noncombustible.

4.3.2 Steel frame members shall be designed so the maximum combined stresses from gravity loads and a 95.8 Pa (2 psf) pressure applied over the entire curtain surface shall not exceed one third of the frame material's yield strength at room temperature. Other frame materials shall be permitted only when allowable stresses are fully documented by an engineering analysis.

4.3.3 The intermediate vertical members shall brace the horizontal members and provide restraint against lateral buckling.

4.3.4 Horizontal members shall be spaced to support face material and bracing for end members.

4.3.5 End members shall have sufficient strength to distribute the lateral forces resulting from the pressure differential to the guide shoes.

4.3.6 Frame member splices shall develop the full strength of the member.

4.4 Guide Assemblies

4.4.1 Each vertical edge of the curtain shall have a minimum of two assemblies to guide the frame within its vertical path of travel.

4.4.2 Guide assemblies shall allow unrestrained expansion of the curtain assembly created by the fire.

4.5 Fire Resistive Cover Material

4.5.1 Either one or both sides of the frame shall be covered with fire resistive materials. Flexible or rigid cover materials such as glass fiber fabric, steel sheet, insulation, or gypsum, singularly or in combination, shall be selected by a qualified person to meet the temperature and strength criteria.

4.5.2. Cover and its attachment shall withstand a minimum horizontal pressure of 95.8 Pa (2 psf) unless higher pressures are required by code.

5 Opening Proximity

5.1 The fire safety curtain in a straight lift fire safety curtain system shall be a maximum of 102 mm (4 inches) from the proscenium wall.

5.2 The top part of a multi-part fire safety curtain shall be a maximum of 102 mm (4 inches) from the proscenium wall.

5.3 The fire safety curtain in a brail fire safety curtain system shall be a maximum of 203 mm (8 inches) from the proscenium wall.

5.4 The distance shall be measured from the proscenium wall to the center of the upper batten on unframed fire safety curtains or to the surface nearest the wall on framed fire safety curtains. The measurement shall be from the stage side of the proscenium wall inside the smoke pocket area to the center of the upper batten on unframed curtains; on framed curtains, the measurement shall be made from the stage side of the proscenium wall inside the smoke pocket area to the surface nearest the proscenium wall.

6 Vertical Edges

6.1 The vertical edges of unframed fire safety curtains shall overlap the proscenium wall a minimum of 457 mm (18 inches). The measurement shall be with the curtain closed and without a pressure differential.

6.2 The vertical edges of framed fire safety curtains shall overlap the proscenium wall a minimum of 152 mm (6 inches). The measurement shall be with the curtain closed and without a pressure differential.

6.3 The vertical guide pocket shall overlap unframed fire safety curtains a minimum of 305 mm (12 inches).

6.4 The vertical guide pocket shall overlap framed fire safety curtains a minimum of 152 mm (6 inches).

6.5 Vertical guide pockets shall protect the vertical edges and guide system of a fire safety curtain from interference between the fire safety curtain and people, stage curtains, scenery, or other items.

6.6 The vertical guide pockets shall be attached to the proscenium wall and shall not interfere with movement of the fire safety curtain. Vertical guide pockets shall be designed to withstand anticipated loads.

6.7 Access for servicing the curtain and vertical guide shall be provided by means of a movable or removable panel for a minimum of 3.05 m (10 feet) above the floor for an unframed and brail fire safety curtain and the full height for a framed fire safety curtain when closed.

6.8 The vertical guide pockets shall extend vertically to protect the entire edge of the fire safety curtain throughout its range of travel and shall include allowance for over-travel.

6.9 Vertical guide pockets shall be permitted to support guide components.

6.10 Guides shall be designed and installed to withstand the forces 95.8 Pa (2 psf) pressure differential applied to the fire safety curtain and maintain an overlap of the proscenium wall. (See Annex note B.6.10.)

7 Horizontal Edges

7.1 Fire safety curtains shall overlap the proscenium wall above the opening by a minimum of 457 mm (18 inches) in the closed position with no pressure differential.

7.2 Multi-part fire safety curtains with non-continuous edges within the proscenium opening shall overlap each other by a minimum of 457 mm (18 inches) where unframed, and a minimum of 305 mm (12 inches) where framed. The measurement shall be with the curtain closed and without a pressure differential.

8 Bumpers

There shall be a minimum 76.2 mm (3 inches) thick bumper made with an outer covering of the same material as the fire safety curtain fabric, filled with noncombustible materials to a 48.1 kg per cubic meter (3 pound per cubic foot) density. The bumper shall be affixed beneath the bottom frame member of framed fire safety curtains or sewn beneath the bottom batten of unframed fire safety curtains.

9 Battens

9.1 The top batten in unframed fire safety curtains shall be designed to limit vertical deflection to 1/180 of the span between supports with no pressure differential.

9.2 The bottom batten in unframed fire safety curtains shall weigh a minimum of 5.43 kg/m (3.65 pounds/foot) .

10 Rigging

10.1 Non-emergency opening and closing shall be powered except straight lift unframed fire safety curtain systems for proscenium openings less than (85.9 m²) 925 square feet shall be permitted to be unpowered.

10.2 All lifting and load supporting components shall be fabricated of noncombustible materials

10.3 All components shall be installed as recommended by the manufacturer.

10.4 Rigging shall be designed by a qualified person.

10.5 Brail fire safety curtains shall be installed with a suspension system attached to structural framing to support the curtain. This suspension system shall be in addition to the system used for hoisting.

10.6 Lift line spacing for brail fire safety curtains shall not exceed 2.44 m (8 feet) and the end hoisting lines shall be a maximum of 610 mm (24 inches) from the vertical edge of the curtain.

10.7 Where a manual winch is used the handle shall not rotate during emergency closing.

11 Operation

11.1 The fire safety curtain system shall be capable of emergency closing and non-emergency opening and closing.

11.2 Emergency closing shall be initiated by both automatic and manual means independently.

11.3 Automatic closing shall be initiated only by the detection of fire on stage. Detection shall use fusible links, electronic heat detectors, sprinkler flow detection, or combination thereof.

11.3.1 Fusible links shall comply with the following criteria.

11.3.1.1 Fusible links shall be listed.

11.3.1.2 The selection of links shall depend on the temperature and load requirements of the application.

11.3.1.3 Separation of a single link shall initiate closing.

11.3.1.4 Links shall not be painted.

11.3.1.5 Links shall be incorporated in a release line. Links shall be evenly spaced along both vertical segments of the proscenium opening and below the roof framing above the proscenium opening.

11.3.1.6 There shall be a minimum of four links, two above, and one on each vertical edge of the opening. One link shall be installed every 4.6 m (15 feet) or portion thereof in the vertical segment, and every 4.6 m (15 feet) or portion thereof of the proscenium opening width.

11.3.2 Electronic heat detectors shall be installed in accordance with NFPA 72-2006 National Fire Alarm Code. (See Annex note B.11.3.2.)

11.3.2.1 Electronic rate of rise detectors shall be rated for 8.33 - 11.1 degrees C (15-20 degrees F) per minute.

11.3.2.2 Electronic fixed-temperature heat detectors shall be selected based upon the temperature requirements of the application.

11.3.3 Sprinkler system flow detection devices shall be installed in accordance with NFPA 13-2006.

11.4 Manual release systems shall include a minimum of two operator stations that initiate emergency closing.

11.4.1 A manual release station shall be installed at both sides of the proscenium opening. Stations shall be unobstructed, visible and operable from stage floor level.

11.4.2 The emergency manual release device shall be painted red per ANSI Z535.1, Safety Color Code.

11.4.3 Operations requiring cutting or severing a line are not permitted.

11.4.4 Manual emergency operation shall be accomplished by a single person

11.4.5 A sign shall clearly identify the device and its operation. (See Annex note B.11.4.5.)

11.5 Standby or emergency power per NFPA 70-2005 shall be provided if power is required for emergency closing.

11.6 Non-emergency closing and opening shall not affect or disable emergency closing systems or devices.

11.7 Non-emergency operation shall be accomplished by a single person.

11.8 Non-emergency operation shall require not more than 3 minutes.

11.9 Where resetting is required after emergency closing or testing, the procedures for resetting shall require no more than two persons. Resetting shall be accomplished without the need for tools, ladders, or other equipment. Use of equipment shall be permitted for replacing fusible links and the resetting of electrical release devices.

11.10 In emergency closing, the curtain shall close from any position to the full closed position at an average speed of not less than 0.305 m/second (1 foot/second). The last 2.44 m (8 feet) of travel shall require a minimum of 5 seconds. (See Annex note B.11.10.)

11.11 Emergency closing speed shall be either governed during the curtain's entire travel, or shall be decelerated for the last 2.44 m (8 feet) of its travel. Deceleration shall be accomplished by dashpot, mechanical brake, or other device. Removing weight from the curtain side or adding weight to the counterweight side is not permitted for achieving deceleration. (See Annex note B.11.11.)

11.12 All fire safety curtains shall be in the closed position except during events with an audience, rehearsals, technical production activity, or activities on stage that necessitate the curtain be open. (See Annex note B.11.12.)

11.13 All labeling and signage required in this section shall comply with the requirements of the following recognized national standards:

ANSI Z535.1-2006, Safety Color Code

ANSI Z535.2-2006, Environmental and Facility Safety Sign

ANSI Z535.3-2006, Criteria for Safety Symbols

ANSI Z535.4-2006, Product Safety Signs and Labels

11.14 Signs or labels shall be in English. If operating personnel are not English literate, additional signs or labels in the appropriate language shall be provided.

12 Testing, Training, Maintenance, Inspection, and Repairs

12.1 Records

A log shall be provided with each fire safety curtain system installed. The log shall include the date of installation, name of the installing contractor, instructions for maintenance, testing, manual emergency closing, and manual operation. All tests and maintenance activities shall be recorded in the log. For fire safety curtain systems where the operation is modified, the manual shall be updated or replaced. The log shall be maintained and shall be made available to the authority having jurisdiction for inspection.

12.2 Pre-Acceptance Testing

12.2.1 Emergency closing and non-emergency operation shall be demonstrated. The authority having jurisdiction shall be notified of the time and place of the demonstration. The demonstration shall include successfully passing the test for emergency closing a minimum of three consecutive times. All emergency operation devices shall be demonstrated at least once. Manual release of fusible link cabling to demonstrate proper operation shall be permitted.

12.2.2 Prior to final acceptance, the Owner or a designated representative shall be trained by a qualified person on the operation, maintenance, and testing requirements of the fire safety curtain system.

12.3 Periodic User Testing

The emergency closing of the fire safety curtain system shall be tested at least once every 30 performances but not less than once every three months.

12.4 Annual Inspection

12.4.1 A qualified person shall inspect the fire safety curtain system at least once a year.

12.4.2 Inspection shall include complete visual inspection of the curtain, rigging, and both the automatic and manual initiating and release devices.

12.4.3 Emergency manual closing shall be tested including testing each manual emergency release device at least once.

12.4.4 The log shall be reviewed by the qualified person.

12.4.5 The owner or the owner's designated representative shall be trained by a qualified person on the operation, maintenance, and testing requirements of the fire safety curtain system as a part of each annual inspection.

12.4.6 The authority having jurisdiction shall be notified of the time and place of the annual inspection.

12.5 Maintenance

Devices with finite life spans shall be replaced per the manufacturer's recommendations. Such devices shall include, but not be limited to, fusible links, batteries, lubricants, fluids, and organic fiber lines.

12.6 Repairs

Unless alternate measures approved by the authority having jurisdiction are in place, deficiencies found that affect the emergency closing of the fire safety curtain system or adversely affect the permeability or performance of the fire safety curtain shall be repaired and user-tested (per 11.2) before the theater is occupied for an event with an audience. Other deficiencies shall be repaired within 30 days. Repairs shall be recorded in the Owner's Log and kept on file by the Owner.

Annex A, Examples

This Annex contains examples of prescriptive designs based on fire safety curtains and standards commonly used in the United States and is not a part of the requirements of this standard. It is included for informational purposes only. As the understanding and knowledge about fire safety curtain systems increases based on research and experience, dependence on these examples should lessen. The prescriptive designs in this Annex are limited to the design examples and are not general requirements to be applied to all fire safety curtain systems.

A.1 Fabric Fire Safety Curtain Construction

A.1.1 Fabric curtains shall be made of continuous vertical strips of fabric sewn together with no horizontal seams.

A.1.2 All seams and other functional stitching shall use a minimum of 25.4 mm (1 inch) wide overlap construction with two rows of lockstitch stitching using flame-resistant thread or an alternative construction with equivalent or superior performance. A sample shall be tested per 3.4.

A.1.3 Vertical edge hems shall have a minimum of three layers of fabric. The hem shall be of uniform thickness and width where guide members or metal reinforcements are attached.

A.2 Unframed Straight-lift Fire Safety Curtain Systems

A.2.1 For proscenium openings with a maximum width of 15.2 m (50 feet) and a maximum height of 9.14 m (30 feet) and where there is a minimum clear height for the fire safety curtain system of twice the height of the proscenium opening plus 1.52 m (5 feet), an unframed Straight-Lift fire safety curtain system with roller guides shall be permitted. Guides shall use continuous tracks with captive trolleys or rollers at each vertical edge of the curtain. Trolleys or rollers shall be attached to the vertical edges of the fire safety curtain with a minimum of three fasteners not more than 457 mm (18 inches) on center.

A.2.2 For proscenium openings with a maximum width of 12.8 m (42 feet) and a maximum height of 6.7 m (22 feet) and where there is a minimum clear height for the fire safety curtain system of twice the height of the proscenium opening plus 1.52 m (5 feet), an unframed straight-lift fire safety curtain system with cable spool guides shall be permitted. Spool guides shall be attached to the vertical edge of the fire safety curtain not more than 457 mm (18 inches) on center.

A.2.3 There shall be metal edge reinforcements fabricated of 16 gauge galvanized steel a minimum of 152 mm (6 inches) wide on both faces of the fire safety curtain, and bolted to the vertical edge hem of the fire safety curtain. The bolts used to attach the guides shall also be permitted for attaching the metal reinforcing to the curtain. Fasteners shall be minimum 6.35 mm (0.25 inch) diameter SAE J 429 Grade 5.

A.2.4 The top and bottom battens shall be minimum 60 mm O.D. (2 inches nominal) schedule 40 steel pipe.

A.2.5 Wire rope guides shall be minimum 6.35 mm (0.25 inch) diameter at each vertical edge of the curtain, anchored top and bottom.

A.2.6 Vertical guide pockets shall be constructed of steel and shall enclose the edge of and overlap the fire safety curtain by a minimum of 305 mm (12 inches) for the full extent of the fire safety curtain throughout its travel plus 305 mm (12 inches). The vertical guide pockets shall be a steel channel fastened to the proscenium wall and have a minimum 6.35 mm (0.25 inch) steel plate attached to the other flange or shall be a one piece bent 6.35 mm (0.25 inch) steel plate. The vertical guide pocket shall be a minimum of 152 mm (6 inches) in depth, measured perpendicular from the proscenium wall. Where a plate is attached to a channel, the attachment shall be bolted connections with bolt spacing not greater than 610 mm (24 inches) on center. The vertical guide pockets shall be fastened to the proscenium wall constructed

of solid 4000 PSI concrete with anchors made of minimum AISI 1018 or 12L14 steel, SAE J 429 Grade 5 fasteners, or other rated fasteners as appropriate for the substrate. Anchors and fasteners shall be spaced not more than 1.22 m (4 feet) on center and shall be selected to resist all forces imposed by the fire safety curtain.

The hardware specified in this section for attaching the Vertical Guide Pocket to the proscenium wall using wedge type anchors, or metal to metal connections. As wall constructions vary, it is incumbent upon designers and contractors to provide substrate and attachment hardware suitable to resist the forces imposed by the Fire Safety Curtain as described in the standard.

A.2.7 Lift lines shall be minimum 6 mm (0.25 inch) 7 X 19 small diameter specialty cord (formerly known as galvanized aircraft cable) conforming to ASTM A1023M-02, Standard Specification for Stranded Carbon Steel Wire Rope for Special Purposes.

A.2.8 Emergency closing speed shall be either governed during the curtain's entire travel, or shall be decelerated for the last 2.44 m (8 feet) of its travel.

A.2.8.1 Descent governors shall limit the rate of descent of the fire safety curtain during automatic closure.

A.2.8.2 Deceleration shall be accomplished by dashpot, mechanical brake, or other device. Removing weight from the curtain side or adding weight to the counterweight side is not permitted for achieving deceleration.

A.2.9 Emergency closing of a manual counterweight fire safety curtain system shall be one of the following types:

A.2.9.1 Overbalance Bar System: An overbalance bar system consists of a pipe or bar that is suspended over the fire safety curtain and is guided by the center two or three lift lines. The suspension system for the bar shall be designed such that the release line holds the bar suspended over the fire safety curtain and, when emergency closing is activated, the bar's weight is dropped onto the fire safety curtain. The bar shall add sufficient weight to achieve emergency closing. Tag lines shall be provided on the bar to facilitate the resetting of the bar after it has been tripped. The overbalance bar shall be capable of being reset by two people maximum.

A.2.9.2 Overbalance Arbor System: The overbalance arbor system consists of a guided weight that is released when emergency closing is activated. The weight of the overbalance arbor acts on the fire safety curtain system counterweight so the combined weight of the fire safety curtain and overbalance arbor is sufficient to activate emergency closing. The overbalance arbor shall be capable of being reset by two people maximum.

A.2.10 Emergency closing of a winch operated fire safety curtain system shall be by clutch release, brake release, or similar mechanism.

A.3 Brail Fire Safety Curtain Systems

A.3.1 The minimum clear height to store the brail fire safety curtain shall be 1.52 m (5 feet) or 125% of the proscenium height, whichever is greater.

A.3.2 The top and bottom battens shall be as for unframed straight lift wire rope guided fire safety curtain.

A.3.3 Wire rope guides shall be as for unframed straight lift wire rope guided fire safety curtain. Edge reinforcement shall not be used.

A.3.4 Vertical guide pockets shall be as for unframed straight lift, wire rope guided fire safety curtains except the vertical guide pocket shall be a minimum of 203 mm (8 inches) in depth measured

perpendicular from the proscenium wall with a minimum of 100 mm (4 inches) between the center of the brail curtain and the back of the guide pocket.

A.3.5 The top batten shall be suspended from structural framing.

A.3.6 Lift lines for brail fire safety curtains shall pass through rings or loops on the surface of the curtain. Lift lines shall attach to the bottom batten.

A.3.7 The brail fire safety curtain system shall use an electric winch.

A.3.8 Activation of the emergency closing shall release a clutch, brake, or similar mechanism holding the fire safety curtain. Emergency closing speed shall be controlled by a governor.

Annex B, Supplemental Information

This annex is not a part of the requirements of this standard, and is included for informational purposes only. It contains explanatory material, numbered to correspond with the applicable text paragraphs.

B.1.2.2 A fire safety curtain system is only one part of an effective life and fire safety plan for a stage in an assembly occupancy. This has been recognized in the US for over 80 years (ref: Letter Circular LC 137, December 13, 1924, US Department of Commerce Bureau of Standards). Current British standards for similar systems also recognize an integrated approach (ref: Technical Standards for Places of Entertainment, Model Technical Regulation, Recommendations E4, District Surveyors Association and ABTT). Contemporary US model fire and building codes have evolved to place greater reliance on fire detection, fire suppression, fire detection and notification systems, smoke management, emergency egress, emergency illumination, type of construction, crowd management, and operations. A fire safety curtain system meeting this standard is most effective if integrated in a coordinated plan. Fire safety curtain systems are limited in effectiveness when used as the sole means of protection. Fire Safety Curtain systems are most effective when efficient extraction ventilation is provided above the stage.

B.2.7 Other styles or types of fire safety curtains such as trip or roller systems have been constructed and installed. Because of difficulties in reliability, these types are no longer recommended but are permitted to be repaired or replaced subject to specific approval of the authority having jurisdiction.

B.2.19 Historically, the vertical guide pocket was presumed to contribute to the retardation of smoke movement through the proscenium opening and was called a smoke pocket.

B.3.1 The means for identifying listed equipment may vary for each organization concerned with product evaluation; some organizations do not recognize equipment as listed unless it is also labeled. The authority having jurisdiction should utilize the system employed by the listing organization to identify a listed product.

B.3.2.1 The application of ASTM D5034-95(2001) Standard Test Method for Breaking Strength and Elongation of Textile Fabrics (Grab Test) to glass or other similar brittle-fiber fabrics requires special methods of attaching or gripping the tested fabric to the testing machine, since the standard testing methods will cause premature failure of the fibers at the jaw. Testing of fabrics for compliance with this standard shall require modification of the standard testing procedures by the use of either (a) padded jaws, (b) rubber jaws, or (c) gluing of the fabric in a manner such that the fabric failure is not at the jaws and a result of the deformation and distress caused by the jaws but instead tests the fabrics strength.

B.3.3.1 Exposed cut edges can unravel and should be hemmed.

B.4.3.6 Not more than half of all splices in parallel frame members should align in planes perpendicular to the fire safety curtain.

B.6.10 Guide systems that restrain the edge of the curtain continuously are more likely to overlap the fire safety curtain with the proscenium wall when the fire safety curtain bulges under unequal atmospheric pressures. The natural deflection (hour-glassing) of the common unrestrained wire rope guide system requires limiting the use of this system to fire safety curtain systems for smaller sized proscenium openings where the total pressure is less and the length of the wire rope guide is limited.

B.11.3.2 It is not uncommon for stage effects to include smoke and fog produced intentionally for theatrical effect. In some jurisdictions, the release of the fire safety curtain is required to be interconnected to the building fire detection system. Care in the selection and arrangement of rate-of-rise and/or fixed temperature heat detectors should be exercised to assure that (a) normal stage use of smoke and fog does not activate the emergency release of the fire safety curtain and (b) that a signal from a detector other than in the stage area does not activate the emergency closing release of the fire safety curtain.

B.11.4.5 The following figure is an example of the sign adjacent to an emergency closing device.

In Case of Fire,
Pull Red Ring to
Lower Fire Safety Curtain

B.11.10 The limit on velocity for 2.44 m (8 feet) above the floor is intended to prevent or lessen injury to occupants in the path of closing.

B.11.11 The greater the overbalance of the fire safety curtain the more probable the fire safety curtain will close irrespective of the effects of atmospheric pressure, time, lack of maintenance, and minor obstructions in its path. Speed governors or checking systems more readily permit a greater overbalance of the fire safety curtain and thus generally are more reliable in assuring the fire safety curtain will close in an emergency than overbalance systems that physically add weight to put the curtain out of balance.

The most common governor is a closed loop hydraulic design where a pump is driven by the closing of the fire safety curtain, either connected to the shaft of a winch or to a traction driven head block, and the speed governed by a valve and reservoir. Adjusting the valve permits using the pump as a governor to closing speed.

B.11.12 Having the fire safety curtain assembly in a closed position has many advantages: first, the fire safety curtain gets moved and used helping to assure that during an emergency the fire safety curtain should perform as expected; second, if there is a problem with the fire safety curtain it will be noticed while being closed or reset; third, it keeps the technicians, janitors, and users conscious of the fact that there is a fire safety curtain and the area below it along with the smoke pockets needs to be kept clear of obstructions; and fourth, it gets the technicians, janitors, and users used to operating the fire safety curtain and through this use they become familiar with the fire safety curtain and its workings and they will become less afraid to use or possibly overlook this piece of safety equipment. If there is a problem closing or resetting the fire safety curtain it will be noticed and maintenance can be performed in a timely fashion.